

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	<u>GENERAL NATIVIDAD WATER DISTRICT</u>	WMAR No :	<u>21-0837A</u>
Owner/Manager :	<u>MARY JANE S. VERA</u>	Date Received :	<u>12/14/2021</u>
Address :	<u>POBLACION GENERAL NATIVIDAD NUEVA ECIJA</u>	Date Analyzed :	<u>12/14/2021</u>
		Date Completed :	<u>12/16/2021</u>

Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform		Thermotolerant Coliform / E. coli	Remarks
				(MPN/100mL)			
Julie Gay Pascua	Talabutab Norte	December 14, 2021 6:00AM	<1	<1.1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
1. Test method used:
 - a. Pour Plate Method for the determination of Heterotrophic Plate Count
 - b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 2. References:
 - a. Philippine National Standards for Drinking Water, 2017
 - b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 3. Result of examination specifically relates to samples as received


Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	<u>GENERAL NATIVIDAD WATER DISTRICT</u>	WMAR No :	<u>21-0837B</u>
Owner/Manager :	<u>MARY JANE S. VERA</u>	Date Received :	<u>12/14/2021</u>
Address	<u>POBLACION GENERAL NATIVIDAD NUEVA ECIJA</u>	Date Analyzed :	<u>12/14/2021</u>
		Date Completed :	<u>12/16/2021</u>

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform		Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)			
Myra Centeno	Balangkare Norte	December 14, 2021 6:30AM	<1	<1.1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	<1.1	


Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
1. Test method used:
 - a. Pour Plate Method for the determination of Heterotrophic Plate Count
 - b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/*E. coli*
 2. References:
 - a. Philippine National Standards for Drinking Water, 2017
 - b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 3. Result of examination specifically relates to samples as received



Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303



Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	<u>GENERAL NATIVIDAD WATER DISTRICT</u>	WMAR No :	<u>21-0837C</u>
Owner/Manager :	<u>MARY JANE S. VERA</u>	Date Received :	<u>12/14/2021</u>
Address	<u>POBLACION GENERAL NATIVIDAD NUEVA ECIJA</u>	Date Analyzed :	<u>12/14/2021</u>
		Date Completed :	<u>12/16/2021</u>

Physical Characteristics : **Sample is clear, with no foreign matter**

Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform		Thermotolerant Coliform / E. coli	Remarks
				(MPN/100mL)			
Maribel Tampengco	Sampaloc	December 14, 2021 7:00AM	<1	<1.1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	<1.1	


Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
1. Test method used:
 - a. Pour Plate Method for the determination of Heterotrophic Plate Count
 - b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/E.coli
 2. References:
 - a. Philippine National Standards for Drinking Water, 2017
 - b. Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF
 3. Result of examination specifically relates to samples as received



Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303



Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal

WATER MICROBIOLOGY ANALYSIS REPORT

Client :	<u>GENERAL NATIVIDAD WATER DISTRICT</u>	WMAR No :	<u>21-0837D</u>
Owner/Manager :	<u>MARY JANE S. VERA</u>	Date Received :	<u>12/14/2021</u>
Address	<u>POBLACION GENERAL NATIVIDAD NUEVA ECIJA</u>	Date Analyzed :	<u>12/14/2021</u>
		Date Completed :	<u>12/16/2021</u>

Physical Characteristics : **Sample is clear, with no foreign matter**


Sample Name	Address	Date and Time of Sampling	Heterotrophic Plate Count (Est. CFU/mL)	Total Coliform		Thermotolerant Coliform / <i>E. coli</i>	Remarks
				(MPN/100mL)			
Rodolfo Flores	Mataas na Kahoy	December 14, 2021 7:30AM	<1	<1.1	<1.1	<1.1	PASSED
PNSDW Limits AO 2017-0010			<500	<1.1	<1.1	<1.1	

Est. CFU/mL = Estimated Colony Forming Units per milliliter

MPN/100mL = Most Probable Number per 100 milliliters

- Note :
1. Test method used:
 - a. Pour Plate Method for the determination of Heterotrophic Plate Count
 - b. Multiple Tube Fermentation Technique for the determination of Total Coliform and Thermotolerant Coliform/*E.coli*
 2. References:
 - a. *Philippine National Standards for Drinking Water, 2017*
 - b. *Standard Methods for the Examination of Water and Wastewater, 22nd Edition, 2012, APHA, AWWA, WEF*
 3. Result of examination **specifically relates to samples as received**


Veronica A. Presentacion, RMicro
Analyst, PAM No. 18-00303


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory, PRC No. 64242

Not Valid Without Dry Seal